



- Note:
1. 50mm strip of neutral cure silicon sealant must be provided at the termination point of all Z flashings at windows, corner boxes, etc.
 2. Detail is only suitable for drained cavities up to two storeys or 7m in height. For drained cavities over two storeys or 7 m in height refer to detail SC018 Horizontal Joint – Non Continuous (Cavity)
 3. Back flashings or 150mm overlap required at all horizontal flashing butt joints
 4. Treat all Shadowclad cut edges with Holdfast® Metalex® Clear

SC016: Shadowclad® Mid Floor Horizontal Joint (Cavity)